

APPENDIX I: CAPACITY CONFIRMATION FROM ESKOM

From: Sunell Botes <sbotes@sanmiguelfglobal.com>
Sent: Thursday, 30 March 2017 11:36 AM
To: Sandra Wren
Cc: Rory Niven
Subject: FW: Navraag

Hi Sandy

See answer below please for question regarding Syl B electricity.

Regards,

QUESTION:

Electrical Infrastructure – Please indicate on whose property the eskom connection point is located. We will need the capacity of the line extension to be installed and any transformers, if required, in kilovolts **NOT** kVA. We will also require confirmation from Eskom that there is existing capacity on this line for the new installation. **Louis can you help us please with this?**

ANSWER BELOW



Sunell Botes
Project/ CI Engineer

Head Office: (+27) 41 368 9015
Cell : +27 84 367 4842
Ground 1, B Block, Walmer Park Office Suites
16th Avenue Walmer, Port Elizabeth-South Africa
www.sanmiguelfglobal.com

From: Andre Mostert [<mailto:MostertA@eskom.co.za>]
Sent: 30 March 2017 09:37 AM
To: Louis de Bruin <LdeBruin@sanmiguelfglobal.com>
Subject: RE: Navraag

Hi Louis

Ons beplanner het laat weet daar is tans genoeg kapasiteit op die Nooitgedacht Skilpad 1 22kV lyn om jou met 150kVA te kan voorsien. Die transformator wat jou met 150kVA sal bedien sal 'n 200kVA 22kV/400V transformator wees.

Baie dankie